




PASSAIC VALLEY WATER COMMISSION

2010 Water Quality Report

Passaic Valley Water Commission's (PVWC) Post Brook Water System is supplied by two groundwater wells (the Nosenzo Pond Wells), which are located within the Post Brook community in a well house designed and constructed by PVWC.

Open public meetings are held monthly. For dates, times and locations of these meetings, call our Customer Service Department at (973) 340-4300.



2010 WATER QUALITY REPORT

PVWC is required to distribute an annual Water Quality Report, or Consumer Confidence Report, to each customer as a result of amendments made in 1996 to the Safe Drinking Water Act. This Report provides a summary of information collected during the calendar year 2010 regarding compliance monitoring required by both the United States Environmental Protection Agency (USEPA) and the New Jersey Department of Environmental Protection (NJDEP). The quality of the water delivered to your service area is represented by the data sets provided for the Nosenzo Pond Wells and in the Post Brook distribution system.



TECHNICAL DATA TABLES

The data presented in this Report are from the most recent testing done in accordance with the regulations. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old. The data tables present concentrations of detected contaminants at the effluent of the wells and in the distribution system, typical sources of contaminants in drinking water, status of compliance with primary and secondary drinking water standards, and related health information when compliance was not achieved.



RADON

Radon is a radioactive gas that you can't see, taste, or smell. It is found throughout the U.S. Radon can move up through the ground and into a home through cracks and holes in the foundation. Radon can build up to high levels in all types of homes. Radon can also get into indoor air when released from tap water from showering, washing dishes, and other household activities. Compared to radon entering the home through soil, radon entering the home through tap water will in most cases be a small source of radon in indoor air. Radon is a known human carcinogen. Breathing air containing radon can lead to lung cancer. Drinking water containing radon may also cause increased risk of stomach cancer. If you are concerned about radon in your home, test the air in your home. Testing is inexpensive and easy. You should pursue radon removal for your home if the level of radon in your air is 4 picocuries per liter of air (pCi/L) or higher. There are simple ways to fix a radon problem that aren't too costly. For additional information, call the State radon program (800-648-0394) or call EPA's Radon Hotline (800-SOS-RADON).

SOURCE OF CONTAMINANTS FOR TAP AND BOTTLED WATER



Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at 800-426-4791. The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit

the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

SPECIAL CONSIDERATIONS REGARDING CHILDREN, PREGNANT WOMEN, NURSING MOTHERS AND OTHERS

Children may receive a slightly higher amount of a contaminant present in the water than do adults, on a body weight basis, because they may drink a greater amount of water per pound of body weight than do adults. For this reason, reproductive or developmental effects are used for calculating a drinking water standard if these effects occur at lower levels than other health effects of concern. If there is insufficient toxicity information for a chemical (for example, lack of data on reproductive or developmental effects), an extra uncertainty factor may be incorporated into the calculation of the drinking water standard, thus making the standard more stringent, to account for additional uncertainties regarding these effects. In the cases of lead and nitrate, effects on infants and children are the health endpoints upon which the standards are based.




Table 1. Water Quality Results Table of Detected Primary Contaminants - 2010 **POST BROOK PWS ID NJ1615008**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

PRIMARY CONTAMINANTS	COMPLIANCE ACHIEVED	MCLG	MCL	SAMPLE RESULTS	TYPICAL SOURCE
				NOSENZO POND WELLS	
INORGANIC CONTAMINANTS					
Barium (ppm)	Yes	2	2	0.024	Erosion of natural deposits.
Chromium (ppb)	Yes	100	100	6	Erosion of natural deposits.
Nickel (ppb)	NA	NA	NA	3	Erosion of natural deposits.
RADIOLOGICAL CONTAMINANTS - 2007 DATA					
Gross Alpha (pCi/L)	Yes	0	15	5.83 (ND - 5.83)	Erosion of natural deposits.
Combined Radium (pCi/L)	Yes	0	5	2.44 (ND - 2.44)	Erosion of natural deposits.
PRIMARY CONTAMINANTS	Compliance Achieved	MCLG	MCL	DISTRIBUTION SYSTEM SAMPLES	TYPICAL SOURCE
DISINFECTION BYPRODUCTS					
Total Trihalomethanes (TTHM) (ppb)	Yes	NA	80	10	Byproduct of drinking water chlorination.
Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys or central nervous systems and may have an increased risk of getting cancer.					
DISINFECTANTS					
Chlorine (ppm)	Yes	MRDLG=4	MRDL=4	0.64 RAA (Range 0.45 - 0.82)	Water additive used to control microbes.
LEAD AND COPPER		MCLG	Action Level	90th Percentile (2009 Data)	
Copper (ppm)	Yes	1.3	1.3	0.101 (0 of 9 samples exceeded AL)	Corrosion of household plumbing systems.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Passaic Valley Water Commission is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at <http://www.epa.gov/safewater/lead>.

The Safe Drinking Water Act regulations allow monitoring waivers to reduce or eliminate the monitoring requirements for asbestos, volatile organic chemicals and synthetic organic chemicals. PVWC's Post Brook water system received a monitoring waiver for asbestos and synthetic organic chemicals for the compliance period 2008-2010.

SOURCE WATER ASSESSMENT

The New Jersey Department of Environmental Protection (NJDEP) has prepared Source Water Assessment reports and summaries for all public water systems. The Source Water Assessment, and related questions, for the Passaic Valley Water Commission's Post Brook Water System (PWS ID 1615008) can be obtained by logging onto NJDEP's source water assessment web site at <http://www.state.nj.us/dep/swap/assessments.htm> or by contacting NJDEP's Bureau of Safe Drinking Water at 609-292-5550. If a system is rated highly susceptible for a contamination category, it does not mean a customer is – or will be – consuming contaminated water. The rating reflects the potential for contamination of source water, not the existence of contamination. Public water systems are required to monitor for regulated contaminants and to install treatment if any contaminants are detected at frequencies and concentrations above allowable levels. The source water assessment performed on the Post Brook System wells lists the following susceptibility ratings as indicated in Table 2.

Table 2. Susceptibility Ratings

Sources	Pathogens	Nutrients	Pesticides	Volatile Organic Compounds	Inorganics	Radionuclides	Radon	Disinfection Byproduct Precursors
4 Wells	2 – Medium 2 - Low	1 – High 3 - Medium	4 - Low	4 - Low	2 – Medium 2 - Low	4 - Medium	3 - High 1 - Medium	4 - Medium

ADDITIONAL WELL EFFLUENT MONITORING**Table 3. Secondary Parameter Results**

Parameter	RUL	Nosenzo Pond Wells PWS ID NJ1615008	RUL Achieved
Alkalinity, ppm	NA	70	NA
Chloride, ppm	250	178	Yes
Corrosivity	Non-Corrosive (+/-1.0)	Non-Corrosive	Yes
Hardness (as CaCO ₃), ppm	250	373	No
Hardness (as CaCO ₃), grains/ gallon	15	22	No
Manganese, ppb	50	30	Yes
pH	6.5 to 8.5	7.8	Yes
Sodium, ppm	50	20	Yes
Sulfate, ppm	250	11	Yes
Total Dissolved Solids, ppm	500	437	Yes
Zinc, ppb	5,000	47	Yes

Additional inorganic contaminants monitored but not detected in the well effluent in 2010 include aluminum, antimony, arsenic, beryllium, cadmium, cyanide, fluoride, iron, mercury, nitrate, selenium, silver, thallium, ABS/LAS, color and odor.

ADDITIONAL DISTRIBUTION SYSTEM MONITORING**Table 4. Distribution System Radon Results – 2007 Data**

Contaminant	Concentration
Radon, pCi/L	760

Additional contaminants monitored but not detected in the Distribution System include Total Coliform Bacteria and *E.coli* Bacteria.

DEFINITIONS of TERMS and ACRONYMS

AL: Action Level; the concentration of a contaminant, if exceeded, triggers treatment or other requirements which a water system must follow.

CDC: Centers for Disease Control

Disinfection Byproduct Precursors: A common source is naturally occurring organic matter in surface water. Disinfection byproducts are formed when the disinfectants (usually chlorine) used to kill pathogens react with dissolved organic material present in surface water.

EPA: United States Environmental Protection Agency

Inorganic Contaminants: Contaminants such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming. These contaminants may be present in source water.

MCL: Maximum Contaminant Level; the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG: Maximum Contaminant Level Goal; the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Microbial Contaminants/Pathogens: Disease-causing organisms such as bacteria and viruses, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife. Common sources are animal and human fecal wastes. These contaminants may be present in source water.

MRDL: Maximum Residual Disinfectant Level; the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG: Maximum Residual Disinfectant Level Goal; the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contamination.

NA: Not applicable

ND: Not detected

NTU: Nephelometric Turbidity Unit

Nutrients: Compounds, minerals and elements that aid growth, that are both naturally occurring and man-made. Examples include nitrogen and phosphorus.

Organic Contaminants/Volatile Organic Compounds: Compounds, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems. Man-made chemicals used as solvents, degreasers, and gasoline components. Examples include benzene, methyl tertiary butyl ether (MTBE), and vinyl chloride. These compounds may be present in source water.

Pesticides/Herbicides: Man-made chemicals used to control pests, weeds and fungus, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses and may be present in source water. Common sources include land application and manufacturing centers of pesticides. Examples include herbicides such as atrazine, and insecticides such as chlordane.

pCi/L: picocuries per liter (a measure of radioactivity)

ppb: parts per billion

ppm: parts per million

PVWC: Passaic Valley Water Commission

RAA: Running annual average.

Radioactive Contaminants/Radionuclides: Radioactive substances that are both naturally occurring and man-made and may be present in source water; result of oil and gas production and mining activities. Examples include radium and uranium.

Radon: Colorless, odorless, cancer-causing gas that occurs naturally in the environment.

RUL: Recommended Upper Limit; the highest level of a constituent of drinking water that is recommended in order to protect aesthetic quality.

RUL Achieved: Yes entry indicates the state recommended upper limit was not exceeded. A no entry indicates the state recommended upper limit was exceeded.

Sequestering Agent: A phosphate based chemical added to the water to bind iron and/or manganese to prevent precipitation of these compounds.

TT: Treatment Technique; a required process intended to reduce the level of a contaminant in drinking water.

% Removal Ratio: Actual percent removal divided by required percent removal, multiplied by 100.

ADDITIONAL INFORMATIONAL RESOURCES

PVWC's website: www.pvwc.com

USEPA Drinking Water website: www.epa.gov/safewater

NJDEP Water Supply website: www.nj.gov/dep/watersupply


American Water Works Association (AWWA) website: www.awwa.org

PVWC Customer Service Department: 973-340-4300

USEPA Safe Drinking Water Hotline: 800-426-4791

NJDEP Bureau of Safe Drinking Water: 609-292-5550

AWWA New Jersey Section website: www.njajwwa.org



Commissioners:
 Thomas P. DeVita, President, Clifton
 Rigo Sanchez, Vice President, Passaic
 Jeffrey Levine, Treasurer, Paterson
 Menachem Bazian, Secretary, Passaic
 Gloria Kolodziej, Commissioner, Clifton
 Idida Rodriguez, Commissioner, Paterson
 Robert Vannoy, Commissioner, Paterson

Dear Passaic Valley Water Commission Consumer,

Passaic Valley Water Commission (PVWC) is dedicated to providing high-quality drinking water to the citizens and industries of Northeast New Jersey. PVWC has created, and continues to improve, one of the nation's most innovative water treatment facilities. For almost 80 years, PVWC has been dedicated to providing drinking water to our customers at the highest quality, service and reliability, and at a competitive price – all while meeting the highest of drinking water treatment standards to aid in the protection of public health. Today, PVWC's commitment to delivering the highest quality drinking water, reliable service and competitive rates to the more than 52 communities we serve is stronger than ever.

This Water Quality Report was prepared on behalf of all of our consumers in accordance with regulatory requirements established by the US Environmental Protection Agency and the New Jersey Department of Environmental Protection.

If you have any questions related to this report, water quality, water pressure, a construction project or billing, please call our Customer Service Department at 973-340-4300, M-F, 8:30 a.m. to 4:30 p.m. For emergencies, contact 973-340-4300, 24 hours per day, 7 days per week.

Sincerely,
 Thomas P. DeVita, Clifton
 President, Board of Commissioners



Passaic Valley Water Commission
 1525 Main Avenue • P.O. Box 230
 Clifton, NJ 07011

**PRSR STD
 U.S. POSTAGE
 PAID
 PERMIT NO. 1
 ZIP CODE 14304**

This report contains information about your drinking water. If you do not understand it, please have someone translate it for you.

Este informe contiene informacion muy importante sobre su agua beber. Traduzcalo o hable con alguien que lo entienda bien.

આ અહેવાલ મેં તમારા પીવાના પાણી વિષે
 અગત્ય ની માહિતી આપવા મેં આવી છે.
 એનો અર્થુષ્ટ કરો અથવા જેને સમજાવો ખસી
 ટોચ તેની સાથે આઈ ફરો

للعومات في هذا التقرير تحتوي على
 معلومات مهمة عن مياة الشرب التي
 تشربها. من فضلك اذا لم تفهم هذه
 للعومات اطلب من يترجمها لك.