

Last revised:
7/31/2020

Passaic Valley Water Commission Meter Spreads

Dimensions are in Inches

The applicant must have the interior building plumbing prepared for the meter install in a horizontal position.

Meter install includes the meter and two couplings. Additional labor/materials required due to improper plumbing preparation will be billed to the customer's account.

<u>METER SIZE</u>	<u>METER</u>	<u>COUPLINGS</u>	<u>TOTAL SPREAD</u>
5/8 x 3/4	7.5	3.5	11
Full 3/4	9	4	13
1"	10.75	4.25	15
1 1/2" Flange	13	0	13
2" Flange	17	0	17

<u>METER SIZE</u>	<u>METER</u>	<u>STRAINER</u>	<u>TEST TEE</u>	<u>TOTAL SPREAD</u>
3" Turbine	12	6	6	24
3" Compound	17	6	None	23
4" Turbine	14	7.5	5.75	27.25
4" Compound	20	7.5	None	27.5
6" Turbine	18	9	12.25	39.25
6" Compound	24	9	None	33
8" Turbine	20	10	22	52
10" Turbine	26	15	24	65