



CLIFTON STANDARD: (CLIFTON - PASSAIC - LODI - NORTH ARLINGTON - WEST MILFORD)

- 5 1/4" M.R.V.
- 2 1/2" Hose Nozzle - 2.91" PITCH DIAMETER x 8 TPI
- 4 1/2" Steamer Nozzle - 5.760" ODM x 4 TPI
- OPEN LEFT
- Quick-Disconnect Adapter: Harrington Permanent Hydrant Adapter Model HPHA50-45NH/Cap-4.5" Female adapter cut with NH (NST) threads-5.760" ODM x 4TPI x 5" Storz connection /cap or approved equal.

PATERSON STANDARD: (PATERSON - PROSPECT PARK)

- 5 1/4" M.R.V.
- 2 1/2" Hose Nozzle - 2.91" PITCH DIAMETER x 8 TPI
- 4" Steamer Nozzle - 4.828" ODM x 6 TPI
- OPEN RIGHT
- Quick-Disconnect Adapter: Harrington Permanent Hydrant Adapter Model HPHA50-40sp/Cap-4.0" Female adapter cut with special thread-4.828" ODM x 6TPI x 5" Storz connection /cap or approved equal.

NOTES:

1. BACKFILL PER LOCAL JURISDICTION.
2. RETAINER GLANDS SHALL BE INSTALLED ON ALL MECHANICAL JOINTS.
3. SEE THRUST BLOCK DETAILS.

FIRE HYDRANT CONNECTION
(NOT TO SCALE)

PASSAIC VALLEY WATER COMMISSION		
1525 MAIN AVE. CLIFTON, N.J.		TEL:(973) 340-4300
FIRE HYDRANT CONNECTION		
TYPICAL DETAIL		
DESIGNED BY:		DATE: 4/5/21
DRAWN BY: M.R/PAD		SCALE: NOT TO SCALE
CHECKED BY:		DWG. 1 OF 1